



NOTE:
 CORROSION COUPON RACK, CHEMICAL POT FEEDER,
 BY-PASS FILTER, AND SAMPLE COOLER MUST BE
 LOCATED AT OPERATOR LEVEL AWAY FROM ANY
 ELECTRICAL EQUIPMENT

ENSURE DRAIN VALVES ARE INSTALLED IN ALL
 SYSTEM LOW POINTS

**INSTALLATION OF CHEMICAL POT FEEDER, BY-PASS FILTER,
 CORROSION COUPON RACK, AND SAMPLE COOLER**

2002-09-17

Detail 15184.02